

Immanuel Lutheran School – Preparing Students for Life Here and in Eternity

Lead Testing Results for Immanuel Lutheran School, Okawville, IL

Illinois Schools Lead Testing Senate Bill 0550 requires our school to test the water of our school. No water may exceed 5 parts per billion.

Water samples at Immanuel Lutheran School were collected on 11/17/2017. PDC lab did the analysis and reports the following findings.

Lead Concentrations:		Parts per billion:
First Water Fountain in the North Hall	First Draw	1.87
	Second Draw	1.24
Second Water Fountain North Hall	First Draw	1.84
	Second Draw	1.20
Third Water Fountain North Hall	First Draw	2.12
	Second Draw	1.36
Fourth Water Fountain North Hall	First Draw	2.36
	Second Draw	1.99
Water Fountain Room 114 (pre-k)	First Draw	3.79
	Second Draw	1.95
Water Fountain Room 113 (k)	First Draw	15.8
	Second Draw	3.61
Kitchen Faucet West Wall	First Draw	1.27
	Second Draw	1.12
Kitchen Faucet North Wall West Side	First Draw	4.00
	Second Draw	1.47
Kitchen Faucet North Wall East Side	First Draw	2.40
	Second Draw	1.41